




### Top View




1. Meter Yoke  
A.Y. McDonald 770-4--JMMD 44  
Full Port Ball Valve  
Full Port Angled Dual Check
2. Corporation Stop  
A.Y. McDonald 7410BCAPF
3. 1" x 18" Brass Nipple
4. 29" x 59" opening single leaf aluminum door, pedestrian rated (300 lb/ft<sup>2</sup>) S1R029059CD
5. 4" Class 56 D.I.P.
6. 2" drain hole




### Component Detail



### End View



### Pipe detail for taps



## Approved for Production

Project: \_\_\_\_\_ Date: \_\_\_\_\_

Quantity: \_\_\_\_\_ By: \_\_\_\_\_

# BARGER PRECAST

### Specifications

**Concrete:** 5,000 psi minimum strength (28 day)  
**Pipe Penetrations:** All pipe penetrations are placed according to job requirements.  
**Pipe Stands:** N/A  
**Sealant:** N/A  
**Steps:** N/A

## 6 Gang 1" Meter Vault City of Franklin (Non-Traffic)

C.R. Barger & Sons, Inc.  
P.O. Box 370 - Kingston TN 37763  
Phone 888.882.5860 - BargerAndSons.com

Date: 3.082018

Drawn By: Eric Barger

Approx. Empty Vault Weight: 3,100 lbs.